





UKCA Certificate of Constancy of Performance

This is to certify that: D P Garg & Co PVT Ltd

B-210B Phase 2

Noida

District Gautam Budh nagar (U.P)

201305 India

Holds Certificate Number: 0086 CPR 805688

In respect of:

BS EN 179:2008 - Emergency exit devices mechanically operated by either a lever handle or a push pad, for the purpose of achieving a safe exit under an emergency situation on escape routes.

LAL 4083, LAL 4084 & LAL 4085 Escape Locks / Emergency Exit Devices

In compliance with the Regulation (UK) Statutory Instrument 2019 No 465 of the United Kingdom Parliament (Construction Products (Amendment etc.) (EU Exit) Regulations or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product. This certificate was first issued on the date below and will remain valid as long as neither the designated standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

For and on behalf of BSI, an Approved Body for the above Regulation (Approved Body Number 0086):

Shahm Barhom, Group Product Certification Director

First Issued: 2024-09-09 Latest Issue: 2024-09-09

Page: 1 of 3

Effective Date: 2024-09-09



UKCA Certificate of Constancy of Performance

No. 0086 CPR 805688

BS EN 179:2008

Product information

Product reference	Product description				
LAL 4083, LAL 4084 & LAL4085	Escape Locks / Emergency Exit Devices				
Intended use:	For doors on escape routes				
Essential characteristics	Clauses within BS EN 179	Compliance			
Ability to release	4.2.1	Pass			
Durability of ability to release against aging and degradation	4.2.1	Pass			
Self closing ability C (for fire/smoke doors on escape routes)	4.2.1	Pass			
Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes)	4.2.1	Pass			
Resistance to fire E (integrity) and I (insulation) (for fire/smoke doors on escape routes)	4.2.1	Grade B			
Control of Dangerous substances	4.1.29	Pass			
Note:	This details only those essential characteristics as required in the ZA Annex of BS EN 179:2008 and applicable to lever handle or a push pad operation.				

First Issued: 2024-09-09 Effective Date: 2024-09-09

Latest Issue: 2024-09-09

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 805688

BS EN 179:2008

Product information - continued...

Model Reference	Description	Not for fire door use	For fire	door use	Mfg. Loc
LAL4083	Escape lock with square forend	✓		✓	000
LAL4084	Escape lock with square forend	✓		✓	000
LAL4085	Escape lock with radius forend	✓		✓	000

Accessories:

Model Reference	Description	Not for fire door use	For fire door use	Mfg. Loc
EH4083	RTD Lever c/w Radius Backplate – 19mm diameter	✓	✓	000
EH4084	RTD Lever c/w Radius Backplate – 19mm diameter	✓	✓	000
LAA 4083	Split spindle	√	✓	000

First Issued: 2024-09-09 Effective Date: 2024-09-09

Latest Issue: 2024-09-09

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.